

Quidos Preview of an Energy Performance Certificate (EPC)

		Energy rating
		F
PREVIEW ONLY	Certificate number 0000-0000-0000-0000	

Property type	Mid-terrace house
Total floor area	69 square metres

Rules on letting this property

You may not be able to let this property

This property has an energy rating of F. It cannot be let, unless an exemption has been registered. You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Properties can be rented if they have an energy rating from A to E. The [recommendations section](#) sets out changes you can make to improve the property's rating.

energy efficiency rating for this property

this property's current energy rating is F. It has the potential to be A.

[see how to improve this property's energy performance.](#)

core	Energy rating	Current	Potential
2+	A		108 A
1-91	B		
9-80	C		
5-68	D		
9-54	E		
1-38	F	25 F	
-20	G		

the graph shows this property's current and potential energy efficiency.

properties are given a rating from A (most efficient) to G (least efficient).

properties are also given a score. The higher this number, the lower your carbon dioxide (CO₂) emissions are likely to

the average energy rating and score for a property in England and Wales are D (60).

Breakdown of property's energy performance

this section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

each feature is assessed as one of the following:

- very good (most efficient)

- good
- average
- poor
- very poor (least efficient)

when the description says 'assumed', it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Roof	Pitched, no insulation (assumed)	Very poor
Window	Some secondary glazing	Very poor
Main heating	Room heaters, wood logs	Poor
Main heating control	No thermostatic control of room temperature	Poor
hot water	Electric instantaneous at point of use	Very poor
lighting	Low energy lighting in all fixed outlets	Very good
floor	Solid, no insulation (assumed)	N/A
secondary heating	Portable electric heaters (assumed)	N/A

Primary energy use

the primary energy use for this property per year is 535 kilowatt hours per square metre (kWh/m²).

[What is primary energy use?](#)

environmental impact of this property

one of the biggest contributors to climate change is carbon dioxide (CO₂). The energy used for heating, lighting and water in our homes produces over a quarter of the UK's CO₂ emissions.

An average household produces

6 tonnes of CO₂

This property produces

2.2 tonnes of CO₂

This property's potential

-1.9 tonnes of CO₂

production

by making the [recommended changes](#), you could reduce this property's CO2 emissions by 4.1 tonnes per year. This will help to protect the environment.


environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

how to improve this property's energy performance

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from F (25) to A (108).

[What is an energy rating?](#)



Recommendation 1: Flat roof or sloping ceiling insulation

flat roof or sloping ceiling insulation

typical installation cost

£850 - £1,500

typical yearly saving

£450

Potential rating after carrying out recommendation 1

38 | F

Recommendation 2: Internal or external wall insulation

internal or external wall insulation

typical installation cost

£4,000 - £14,000

typical yearly saving

£372

potential rating after carrying out recommendations 1 and 2

53 | E

Recommendation 3: Floor insulation (solid floor)

floor insulation (solid floor)

typical installation cost

£4,000 - £6,000

typical yearly saving

£44

Potential rating after carrying out recommendations 1 to 355 | D

Recommendation 4: Draught proofing

draught proofing

typical installation cost

£80 - £120

typical yearly saving

£23

Potential rating after carrying out recommendations 1 to 457 | D

Recommendation 5: Solar water heating

solar water heating

typical installation cost

£4,000 - £6,000

typical yearly saving

£141

Potential rating after carrying out recommendations 1 to 562 | D

Recommendation 6: Double glazed windows

replace single glazed windows with low-E double glazed windows

typical installation cost

£3,300 - £6,500

typical yearly saving

£161

Potential rating after carrying out recommendations 1 to 669 | C

Recommendation 7: High performance external doors

high performance external doors

typical installation cost

£1,000

typical yearly saving

£32

Potential rating after carrying out recommendations 1 to 7

70 | C

Recommendation 8: Solar photovoltaic panels, 2.5 kWp

solar photovoltaic panels

typical installation cost

£3,500 - £5,500

typical yearly saving

£348

Potential rating after carrying out recommendations 1 to 8

82 | B

Recommendation 9: Wind turbine

wind turbine

typical installation cost

£15,000 - £25,000

typical yearly saving

£720

Potential rating after carrying out recommendations 1 to 9

108 | A

Paying for energy improvements

[and energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

estimated energy use and potential savings

estimated yearly energy cost for this property**£1913****Potential saving****£1221**

the estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

the estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

For advice on how to reduce your energy bills visit [Simple Energy Advice \(https://www.simpleenergyadvice.org.uk/\)](https://www.simpleenergyadvice.org.uk/).

Heating use in this property

Heating a property usually makes up the majority of energy costs.

estimated energy used to heat this property**space heating****17355.0 kWh per year****water heating****1227.0 kWh peryear****potential energy savings by installing insulation****type of insulation****Amount of energy saved****solid wall insulation****3875 kWh per year**

see if you might be able to receive [Renewable Heat Incentive payments \(https://www.gov.uk/domestic-renewable-heat-incentive\)](https://www.gov.uk/domestic-renewable-heat-incentive). This will help to reduce carbon emissions by replacing your existing heating system with one that generate renewable heat. The estimated energy required for space and water heating will form the basis of the payments.

Contacting the assessor and accreditation scheme

Assessment details

Assessor's declaration	No related party
Date of assessment	3 December 2020
Date of certificate	3 December 2020
Type of assessment	► RdSAP